

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Fire Safety Equipment Pty Ltd	Client ID	103334
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.6-2007 : Portable fire extinguishers - Specific requirements for carbon dioxide type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	17/10/2022	Certification Expiry Date	4/02/2028
Certificate Issue Date	18/04/2017	Certificate Last Update Date	16/01/2023

APPROVED COMPANY/SITE ADDRESS(ES):

2A Staple Street Seventeen Mile Rocks QLD 4073 Australia
Wucheyan Huangjiang Town Yuyao Zhejiang - China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: 646F1E8C03A82335CA2589330018BA4E

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:
In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
204	2.0 Kg CO2 Extinguisher	Various	2.0 kg Steel alloy cylinder, Rating: 2B:E, FERN: 3334.6-01	28/05/2021
354	3.5 Kg CO2 Extinguisher	Various	3.5 kg Steel alloy cylinder, Rating: 5B:E, FERN: 3334.6-02	28/05/2021
504	5.0 Kg CO2 Extinguisher	Various	5.0 kg Steel alloy cylinder, Rating: 5B:E, FERN: 3334.6-03	28/05/2021

Comments:

Construction of extinguisher complies with standard AS/NZS1841.1:2007 Portable fire extinguishers Part 1: General requirements.

End of the document



Certification Manager

