

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	Fire Safety Equipment Pty Ltd	Client ID	103334
Company Other Name		Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	17/10/2022	Certification Expiry Date	4/02/2028
Certificate Issue Date	18/04/2017	Certificate Last Update Date	16/01/2023

APPROVED COMPANY/SITE ADDRESS(ES):

2A Staple Street Seventeen Mile Rocks QLD 4073 Australia
Wucheyan Huangjiang Town Yuyao Zhejiang - China

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Unique Certificate Code: 6BB8664DC1A2E3B1CA2589330018ACE3

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:
In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
110	1.0kg Dry powder type extinguisher	Various	1.0kg dry powder, Fire Rating - 1A : 10B : E, FERN: 3334.5-01	7/07/2009
120	1.0kg Dry powder type extinguisher	Various	1.0kg dry powder, Fire Rating - 1A : 20B : E, FERN: 3334.5-02	7/07/2009
150	1.5kg Dry powder type extinguisher	Various	1.5kg dry powder, Fire Rating - 2A : 30B : E, FERN: 3334.5-03	24/11/2009
250	2.5kg Dry powder type extinguisher	Various	2.5kg dry powder, Fire Rating - 3A : 40B : E, FERN: 3334.5-04	24/11/2009
450	4.5kg Dry powder type extinguisher	Various	4.5kg dry powder, Fire Rating - 4A : 60B : E, FERN: 3334.5-05	10/12/2009
900	9.0kg Dry powder type extinguisher	Various	9.0kg dry powder, Fire Rating - 6A : 80B : E, FERN: 3334.5-06	7/07/2009

Comments:

Construction of extinguisher complies with standard AS/NZS1841.1:2007 Portable fire extinguishers Part 1: General requirements.

End of the document



Certification Manager

