



# Y-1260 with XC4003 Controller







## Notes:

- 1 Standard FirePro FP-06100 Bracket used
- 2 Mounted to Existing Steel Bulkhead in Unit
- 3 Holes in Bracket are for M8 Bolts

		FIRE SAFETY EQUIPMENT PTY LTD		
Drawn By	Approved By	Title	Drawing No	Rev.
PM		Atlas Copco Y-1260 CX4003 Controller		
Scale	Date	·	Y-1260-2	В
No	15-10-19	FirePro Aerosol Unit Mounting		

## Y-1260 with XC4003 Controller






## **INSTALLED VIEW**






**FRONT MOUNTED VIEW** 







#### **Notes:**

- 1 Bracket Material Marine Grade Aluminium 2mm Unpainted
- 2 Dimensions are in MM

Panel

Location

- 3 Bracket has Provision for all Control Modules on Front
- 4 Bracket mounts on Predrilled & tapped 8mm holes on floor plate

	FIRE SAFETY EQUIPMENT PTY LTD							
Drawn By	Approved By	Title	Drawing No	Rev.				
PM		Atlas Copco Y-1260 CX4003 Controller						
Scale	Date	•	Y-1260-3	В				
No	15-10-19	FirePro Panel Control Panel Mounting						

Y-1260 with XC4003 Controller								
				BILL OF MA				
Part No FP-3000S	Qty 1		Description 3000g SS Aerosol Generator		Part No FP-08860	Qty 1	FRANCE SAFE  SPEED SCHIZDON MODULE  HER STREET STREET  HER STREET	Description  Shutdown Module - to suit 8451
FP-06100	1	and a second	HD SS Bracket to suit 1200 - 5700		FP-08872	1		Battery Backup Module 12-24vDC NiMH
FP-08800	1	PORCE DESCRIPTION OF THE PROPERTY OF THE PROPE	FirePro Test Module		FP-14053	2	FIRE	External Actuator Switch with Bracket
FP-06910	1		Dust Seals – to suit FP1200-5700		FP-14016	1		Battery cable connection x 3m with 5A Fuse 2 Pin Male Deutsch Plug and Ballery Terminal Connectors
FP-08451	1	Consistence Autorities Representation of Consistence of Consistenc	Control Panel - FirePro detection and Activation Panel		FP-09500	30	<b>24</b>	Cable 2 core 0.75mm Shielded FR x 1m
X-Y1260	1		Special Bracket for Mounting Control Equipment on Atlas Copco Y-1260 Compressor		FP-08825	1		Thermal Fuse with Coupling
DP-3010	2		Deutsch Plug – 3 Pin Male, c/w pins and heatshrink to suit		FP-08940	1	Jane William	Siren / Strobe with EOL diode Installed
DP-3020	2		Deutsch Plug – 3 Pin Female, c/w pins and heatshrink to suit		FP-09510-08	1	0	Linear Heat Detection 180deg C Cable x 8m with 2 pin Deutsch Plugs fitted
DP-2010	4		Deutsch Plug – 2 Pin Male, c/w pins and heatshrink to suit		Misc	16		P-clips to suit FP-09510 LHD
DP-2020	4		Deutsch Plug – 2 Pin Female, c/w pins and heatshrink to suit		FP-08961	1	And a	Sign - System Warning Vinyl - Vehicle
FP-08950	2		End of Line Resistor		FP-08879	1	OPER DISTRICT	Voltage Sensitive Relay
FP-08945	1		WaterProof Enclosure for Control Panel					
					r			FIRE SAFETY EQUIPMENT PTY LTD
						PM Scale	Approved By  Date  15-10-19	Atlas Copco Y-1260 CX4003 Controller Bill of Materials  Drawing No  Y-1260-4  B