Fire Pro. Reinventing Fire Suppression

• FirePro Generators should be aimed at the items likely to be involved in the fire.

AS 5062 Vehicle Protection

Date 12/09/2018

| Fire Suppressi | - | | • | | | | | | | AFP-11.2 | | | | |
|---|---|-------------|------|--|--|-------|------------------|-------|---------------|-----------|------------|-----------|--|--|
| CERTIFICATION | AS 5062 Vehicle Protection | | Mo | | L2 | | Stream Length | Agent | Concentration | | Primary | Secondary | | |
| VEHICLE Make | Dennings 2 axle buses | | IVIO | | mm) (r | | (mm) | Qty | Primary | Secondary | Quantity (| Quantity | | |
| | | | FP-0 | 020 | 0 | .00 | 300 | 20 | - | - | - | - | | |
| Model | 2 axle buses | | FP-0 | 040 | 0 | .00 2 | 1200 | 40 | - | - | - | - | | |
| Risk Area | Engine compartment | | FP-0 | 080 | 0 | .00 2 | 2000 | 80 | - | - | - | - | | |
| Classes of Fire | ✓ Class A ✓ Class B ✓ Class E ☐ Class F | | FP-0 | 100 | 0 | .00 | 1000 | 100 | - | - | - | - | | |
| | | | FP-0 | 200 | 100 | 00 : | 1500 | 200 | - | - | - | - | | |
| | | | FP-0 | | | | 2500 | 500 | 1,000 | - | 2 | - | | |
| STREAM (m) | 2.0 < SL < 4.0 | | FP-1 | | | | 3500 | 1,200 | - | - | - | | | |
| GROSS DIMENSIONS | Not Used Not Used Enter | Vol Entered | FP-2 | _ | | _ | 3500 | 2,000 | - | - | - | - | | |
| (All in Meters) | 0.00 X 0.00 X 0.00 VOLUME = | 4.00 n | | | | | 4000 | 3,000 | - | - | - | • | | |
| | Actual Leakage Meaurement = | 2.00 n | FP-5 | | | | 8000 | 5,700 | - | - | - | • | | |
| | Leakage Allowance without additional Agent = 3.20 m2 | | | Total Concentration 1,000 - Required Concentration 754 - | | | | | | | | | | |
| | | | | % Required Concentration 133% 0% | | | | | | | | | | |
| | GROSS Volume used for Calculation = 4.00 m3 | | | | ✓ Design Calculation has been Confirmed | | | | | | | | | |
| | PRIMARY AGENT DISCHARGE 754.00 g | | | ✓ FirePro Units have suitable STREAM length for Risk Area Coverage | | | | | | | | | | |
| | | | | | ✓ Leakage compensation made in Primary Discharge | | | | | | | | | |
| Secondary Agent Discharge Not Required | | | | | | | | | | | | | | |
| Aust.Std Design Notes | | | | | APPROVED | | | | | | | | | |
| CALCULATION OF VOLUME: Calculation is based on Gross Volume with NO deductions for any Objects that occupy volume within the protected space. The concentration of Aerosol, and leakage allowances is based on Tests conducted in 2010 with Hughes Associates Europe. | | | | Prepared By: Company RJM FSE | | | | | | | | | | |
| Minimum Extinguis | | | | | | | | | | | | | | |
| L3 is the thermal clearaVehicle Systems are com | nce required where the temprature of the discharge is less that nce required where the temprature of the discharge is less that pliant to AS 5062 | | | | | | | | | | | | | |