FirePro. Reinventing Fire Suppression MOBILE PLANT									Date	23/01 F	./2020 lev 20.1	
CERTIFICATION	MOBILE PLANT		Mod	lel	L2	L3	Stream Length	Effective Agent		ntration Secondary	Primary Quantity	Secondary Quantity
CLIENT NAME	Sydney Trains		FP-0	•	nm) 0	(mm)	(mm) 300	Qty 20	_	_	_	_
Vehicle Make / Model	MTPV		FP-0		0	100	1200	40	-	-	_	_
Risk Area	Engine Bay as per drawing FLO174081_S1		FP-0	080	0	100	2000	80	-	-	-	-
Classes of Fire	✓ Class A ✓ Class B ✓ Class E ☐ Class D	☐ Class F	FP-0	100	0	100	1000	100	-	-	-	-
			FP-0	200 1	100	300	1500	200	-	-	-	-
			FP-0		200	500	2500	500	2,000	-	4	-
STREAM (m)	2.0 < Stream Length < 4.0		FP-1		200	1200	3500	1,200	-	-	-	-
GROSS DIMENSIONS (All in Meters)	Length Width Height Enter 3.70 X 2.80 X 0.86 VOLUME	Not Used	FP-2		200	1200	3500	2,000	-	-	-	-
		=	n³ FP-3		700 300	1700 1800	4000 8000	3,000 5,700	-	-	-	-
	Actual Leakage Measurement - M ²	=	n ²					3,700	2,000	_		_
Leakage Allowance without additional Agent = 7.20 m ² GROSS Volume used for Calculation = 8.91 m ³				Total Concentration 2,000 - Required Concentration 1,679 - % Required Concentration 119%								
				PRIMARY AGENT DISCHARGE 1,679 g			g	FirePro Units have suitable STREAM length for Risk Area Coverage				
Secondary Agent Discharge - g				Leakage compensation made in Primary Discharge								
				☐ Additional HOLD time Required for the risk								
Aust.Std Design Notes							A E			<i>/</i> F.F.		
CALCULATION OF VOLUME: Calculation is based on Gross Volume with NO deductions for any Objects that occupy volume within the protected space. The concentration of Aerosol, and leakage				APPROVED								
allowances is based on Tests conducted in 2010 with Hughes Associates Europe. AS 5062. Minimum Extinguishing Factors (mef) 145 X 1.3 = 189				Prepared By: PM							npany SE	
• L2 is the thermal clearance required where the temperature of the discharge is less than 200° C												
 L2 is the thermal clearance required where the temperature of the discharge is less than 75° C Vehicle Systems are compliant to AS 5062 FirePro Generators should be aimed at the items likely to be involved in the fire. 												



