



Note:

1. Fire extinguisher is completed according to the standard GB4351-1984. All tests shall meet the requirements of standard.
2. All accessories for the fire extinguisher shall be inspected before assembly and be ensured they are free of defect such as damage crack .
3. Extinguishing agent: 40% ABC Powder (yellow color) 4±0.08KG.
4. Fire ext. assembly: Filled with powder, but without Nitrogen.
5. Package: 2PCS/CTN 280X145X515CM/CTN
6. Stamp on the foot ring:
ECCO Australia MASA TOTAL x.xKG PS 1.4MPa PE 3.5MPa FAB XX/11 K 201765 (-203364)

9	P4-ZX	Carton	1
8	T02-01-03	Wall Bracket	1
7	T11-02-02	Seal	1
6	T12-xx	Gauge	1
5	T08-01-01	Plastic black Belt	1
4	T16-12-370	Dip tube	1
3	P4-UQ	cylinder	1
2	T15-P4-01	Hose	1
1	YF0205-00D	Valve	1

MODEL 400 4KG 40% ABC Fire Ext.